CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200319 Address: 787 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, July 28, 2020
Corrective Action Required:			

Corrective Action Required:

1 Misc -INSIDE COLUMN LIGHTED FACADE, SECURE MC CABLE WITHIN 12" OF J-BOX

Comments: