

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20200845	Date:	July 28, 2020
Project Title:	ST LUKE'S EAST HOSPITAL FLEX CAPACITY ADDITION	Applicant:	
Location:	80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086	American Fire Sprinkler Corporation 6750 W 47th Terrace Kansas, MO 66203	
Type of Work:		Primary: (913) 722-6900 Ext: 125	
Occupancy Group:	I-2		
Description:	ADDITION TO HOSPITAL		
Construction Type:	Type IA		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test and a flow test.

2. (Action Required)

Provide a 4" Storz connection with a 30 degree elbow for the Fire Dept. Connection

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**