

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192096  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Tuesday, July 28, 2020

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	pre-inspection walk through.
---	----------------------------------	------------------------------

Corrective Action Required:

2	STAIR TOWER 1
---	---------------

Corrective Action Required:

3	STAIR TOWER 2	-STAIRWELL "B"- -1ST FLOOR SHAFT WALL-
---	---------------	---

Corrective Action Required:

4	STAIR TOWER 3	STAIRWELL "C" INSIDE FACE: -1ST LAYER 1ST,2ND,3RD,floors - 2ND LAYER 1ST,2ND, 3RD FLOORS -
---	---------------	--

Corrective Action Required:

5	FIRST FLOOR	- RC AREA "E" CORRIDOR 119 TO RM 124, CORRIDOR 122 - - AREA "E" CORRIDOR LIDS 119, -UNITS FURNACE ROOMS,
---	-------------	---

Corrective Action Required:

6	SECOND FLOOR	- RC AREA "E" CORRIDOR ceiling & wall 219, - AREA "E" CORRIDOR CEILING 219 COMPLETE, 222 ;  - ROCK CORRIDOR WALL 3FT DOWN-219,222 -RC CHANNEL CEILINGS AND DEMISING WALLS COMPLETE ROOMS: 240, 241,
---	--------------	--

242, 244, 245, 261, 263, 264

-243- PROTECTION PLATES AT DWV IN DEMISING WALL

-262- PROTECTION PLATES AT DWV IN DEMISING WALL

Corrective Action Required:

7 THIRD FLOOR

- RC AREA "E" CORRIDOR 319- walls ceiling

- AREA "E" CORRIDOR CEILING

319, 322.

RC CHANNEL- COORIDOR 319,322

CORRIDOR WALL DOWN 3FT

-RC CHANNEL CEILINGS AND DEMISING WALLS COMPLETE ROOMS: 340, 341, 342, 344, 345, 361, 362, 363, 364

-343 PROTECTION PLATES AT SHOWER VALVE IN DEMISING WALL

Corrective Action Required:

8 FOURTH FLOOR

- RC AREA "E" CORRIDOR 419, 422 -

- AREA "E" CORRIDOR LIDS 419 COMPLETE, 422 TO STAIRS -

-RC CHANNEL CEILINGS AND DEMISING WALLS COMPLETE ROOMS:

439,440,441,442,443,459, 461

-460 MISSING RC CHANNEL IN LIVING ROOM, AND SUPPORT AT NORTH WALL

Corrective Action Required:

9 ELEVATOR 1

Corrective Action Required:

10 ELEVATOR 2

Corrective Action Required:

11 ELEVATOR 3

**Comments:**