

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192096  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Partial	Tuesday, July 28, 2020

Corrective Action Required:  
1       FOURTH FLOOR       AREA"E"- UNITS-438439,440,461,441,442,459-443-459-461-462-460-

Corrective Action Required:  
2       THIRD FLOOR       Section "E"  
345-344-343- 342-361-362-363-341-364-340-322-corridor framing ceiling

Corrective Action Required:  
3       SECOND FLOOR       Section "E" Ok-241,242,243,244,245,261,262.  
-264- shower valve box corridor wall incomplete

**Comments:**