

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201007
Address: 128 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, July 28, 2020

Corrective Action Required:

1	Misc	- ADDRESS RAFTERS LANDING ON BLOCKS THROUGHOUT - - PROVIDE ANCHOR BOLTS WITHIN 12" OF PLATE BREAK NEAR UFER IN UNFINISHED AREA BEHIND STAIRS -
---	------	--

Comments: