

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201406  
Address: 4701 NE SARATOGA CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                   | Inspector:   | Outcome: | Date:                  |
|---|--------------|----------|------------------------|
| <b>Sewer Service Inspection - Residential</b> | Khanh Nguyen | Failed   | Tuesday, July 28, 2020 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -PROVIDE GRAVEL SUPPORT FOR SEWER<br>-INSTALL APPROVED SPLICE CONNECTOR FOR SEWER TRACER WIRE |
|---|------|---|

**Comments:**