

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201494
Address: 4720 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, July 29, 2020

Corrective Action Required:

1	Misc	FRAMING: -Brace ends of lvl beam above great room from rotation **above oven MECHANICAL: -Provide combustion air openings per code **OK TO INSULATE
---	------	---

Comments: