

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192215
Address: 3340 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Wednesday, July 29, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE (2) 3" SCREWS AT EACH HINGE AND STRIKE PLATE IN FRONT DOOR-BREAK OFF SET SCREW IN ANTI-SYPHON DEVICE IN BASEMENT -PROVIDE HAMMER ARRESTORS AT LAUNDRY
---	--------------------------	---

Comments: