

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20184050
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Wednesday, July 29, 2020

Corrective Action Required:

2 Misc

Your project is in violation of the Erosion and Sediment control policy. We received an email with pictures of erosion control problems on this site from the Missouri Department of Natural Resources. There appears to be a can of trash that was dumped in the road at a dead end. All the gutter buddies in the curb inlets need to be cleaned out of the mud and silt. Some of them are growing weeds in them. Please take care of these items as soon as possible. Please notify the builders to make sure their erosion control devices are in place.

Comments: