CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182613

Address: 905 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Robb Popp Partial Thursday, July 30, 2020

Commercial

Partial Correction:

1 THE FOLLOWING EXTERIOR SHEAR WALL X, AREAS ARE Elevator walls, ceiling.

APPROVED

Corrective Action Required:

2 STAIR TOWER 1 ROUGH FRAMING 0-4TH FLOOR

ROUGH FRAMING AND ELECTRICAL IN CEILINGS
ALL TRADES ON STAIRWELL WALL ASSEMBLY

Corrective Action Required:

3 STAIR TOWER 2 ROUGH FRAMING 0-4TH FLOOR

ROUGH FRAMING AND ELECTRICAL IN CEILINGS ALL TRADES ON STAIRWELL WALL ASSEMBLY

Corrective Action Required:

4 LOWER LEVEL Corrective Action Required:

5 FIRST FLOOR ROUGH FRAMING IN WALLS FRO DATA ROOM, ELEVATOR MECH. ROOM, AND

ELECTRICAL DATA ROOM

SHEAR WALLS 2,4 AND 6 ALL TRADES COMPLETE

PORCHES ALL TRADES COMPLETE

-INCOMPLETE TRAPS AT SHOWERS IN 101, 103, 107,109,111,115,117 -INCOMPLETE TRAPS IN CORRIDOR OUTSIDE OF G2, G8, G12, AND IN S13 Corrective Action Required:

6 SECOND FLOOR SHEAR WALL 4 AND 6 ALL TRADES COMPLETE

PORCHES ALL TRADES COMPLETE

ALL TRADES COMPLETE

Corrective Action Required:

7 THIRD FLOOR SHEAR WALL 4 ALL TRADES COMPLETE

PORCHES ALL TRADES COMPLETE

ALL TRADES COMPLETE

Corrective Action Required:

8 FOURTH FLOOR 4TH FLOOR COMPLETE

Comments: