

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20191352  
Address: 1305 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Thursday, July 30, 2020

Corrective Action Required:  
2            Misc            -Water meter well needs set at grade, an extension is needed.  
                                     \*\*concrete blocks are used to elevate the top ring&lid to grade level, instead  
                                     of a proper extension.

Corrective Action Required:  
3            Miscellaneous  
                 Correction            -Dish washer receptacle shall be gfci-protected  
   \*\*Install a dual purpose breaker that provides both afci and gfci protection  
  
   -Provide afci protection for circuit supplying outlet in laundry. NEC 210.12

**Comments:**