

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20201001  
Address: 1520 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Friday, July 31, 2020

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- Garage PFH per plans</li><li>- Exterior garage portal strap nails missed interior framing</li><li>- Fireblock vertical to horizontal at furred down for DWV and HVAC in garage</li><li>- (3) 2x4 at corner HVAC to dining room framing per plans</li><li>- Truss hangers per plans</li><li>- EC#2 per plans</li><li>- Connect top plates at top stair landing at 2x6 to 2x4 wall</li><li>- Anchor all columns to floor in basement</li><li>- UFER ground required</li><li>- 3" steel column at stairs missing in basement, pier location "A"</li></ul> |
|---|------|--|

**Comments:**