

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200309
Address: 156 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Friday, July 31, 2020

Informational:
1 Misc Forms were placed and aggregate was present and compacted. They also tore out the curbing in front of the approach. Curbing was removed joint to joint. Rebar was drilled into existing curbing for support. RP 7-22-20

Informational:
2 Misc Finished driveway and new curbing meets LS specs. RP 7-31-20

Comments: