

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192831  
Address: 2916 NW AUDUBON LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Friday, July 31, 2020

Corrective Action Required:

1	Misc	- PROVIDE SOD - - PROVIDE SPLASH BLOCKS - - PROVIDE GFCI PROTECTION DISHWASHER - - GFCI AT BASEMENT PATIO DOOR DEAD - - PROVIDE HARDWARE SLIDING GLASS DOOR DECK - - PROVIDE 1" CLEARANCE B VENT 2ND STORY HVAC CLOSET CHECK COMBUSTION AIR 6" 3' X 6'7" ROOM - - PROVIDE HANDRAIL AT WINDER STAIRS @ ENTRY - - RETAINING WALL OVER 4' ENGINEER LETTER -
---	------	--

Comments: