



July 27, 2020


Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Revision of suspended garage beam size for Lot # 24 Hawthorne Ridge 1513 SW Sugar Tree Dr. Lee's Summit, MO 64082 – Permit # PRRES20201848

This letter addresses the revision to the suspended slab beam sizing.

The revisions shall be as follows:

- Suspended slab beam shall be ASTM A992 (50 ksi yield strength) W10x60 steel beam spanning approximately 19'-8". End supports shall be beam pockets within 10" thick foundation wall.



Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol".

Bradley Huxol, PE

