



June 24, 2020

Summit Homes
120 SE 30th St
Lee's Summit, MO 64082

**RE: Subgrade Inspection for Lot # 18 Hawthorne Ridge – 3012 SW Arboridge Dr
Lee's Summit, MO 64082 – Permit # PRRES20201863**

On June 23, 2020, a special inspection was performed by Residential Engineering Services, LLC (R.E.S.) at the above referenced property. The purpose of this inspection was to verify competent subgrade soils for follow on footings.

- RES visually verified that the extended trench subgrade soils per previous RES recommendations were a competent clay soil with no apparent compaction or moisture issues
- Permit plan footing will be poured on top of existing trench footings per plan specifications
- Extended footings are approved for concrete

We would like to thank you for the opportunity to consult you on your project. Please feel free to contact us if you have any questions regarding this report or need any further consultation.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

