

### **PLANS REVIEW CONDITIONS**

Permit No: PRCOM20200987

Date: August 03, 2020

Project Title: OUR LADY OF THE PRESENTATION -  
INTERIOR ALTERATIONS

Applicant:

Location:

CENTURY FIRE SPRINKLERS, INC

150 NW MURRAY RD, LEES SUMMIT, MO 64081

1901 BEDFORD

Type of Work:

NORTH KANSAS CITY, MO 64116

Occupancy Group: A-3

Primary: (816) 556-0808

Description: INTERIOR ALTERATIONS TO  
EXISTING CHURCH - REMODEL OF WORSHIP SPACE,  
GATHERING SPACE, OFFICES AND MEETING ROOMS

\*\*invite planner to verify rooftop screening

Construction Type: Type IIB (Unprotected)

Map Page:

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Action Required)

Call (816)969-1300 to schedule a hydrostatic test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**