

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182613
Address: 905 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Tuesday, August 04, 2020

Corrective Action Required:

1	Miscellaneous Correction	-ABOVE CEILING FOR FRAMING AND SPRINKLER HEADS 4TH FLOOR PATIOS -FUR DOWN FRAMING AND FIRE CAULK ON 4TH FLOOR UNITS AND G1 AND G19 GARAGES
---	--------------------------	---

Comments: