

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172523  
Address: 245 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Failed	Tuesday, August 04, 2020

Corrective Action Required:	
1 THIRD FLOOR	- RC APPROVED -
Corrective Action Required:	
2 SECOND FLOOR	- RC APPROVED -
Corrective Action Required:	
3 FIRST FLOOR	- RC MISSING SCREWS - - SOUTH STAIR AT RISER PIPE - - NORTH STAIR AT LVL - - G-2 NEAR OVERHEAD DOOR - - G-12 5 ROWS IN MIDDLE -

**Comments:**