

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201466
Address: 4060 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Manhole Adjustment	John Jackson	Partial	Tuesday, August 04, 2020

Informational:
1 Misc 8/4/20 Tuesday see detail sheet c 404 Existing Manhole Wall Connection.
Contractor coring into existing manhole using a gasket for new pipe opening.
Contractor (Beemer Const.) will installed a plug in gasket until the start to install sanitary line.

Comments: