

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201699
Address: 1618 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, August 04, 2020

Corrective Action Required:

1	Misc	INSPECTION DENIED, NO EROSION CONTROL IN PLACE ESTABLISH EROSION CONTROL AROUND LOT BEFORE RESECHEDULING INSPECTION
---	------	---

Comments: