

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191873
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Vacuum	John DiMauro	Passed	Thursday, June 18, 2020

Informational:

1 Misc

John DiMauro 06/18/2020 3:25 PM

I observed the vacuum test for the manholes on sanitary line 1 and the results are as follows:

MH 1-4
less than 10'ft deep
Gauge held at 10 for 2 minutes with no drop
Test Passed

MH 1-5
less than 10'ft deep
Gauge held at 10 for 2 minutes with no drop
Test Passed

Comments: