

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191873
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Air Test	John DiMauro	Passed	Thursday, June 18, 2020

Informational:
1 Misc John DiMauro 06/18/2020 3:18 PM

I observed the sanitary sewer air test for Line 1 and the results are as follows:

Line 1 segment between MH 1-3 & 1-4
Line held at 4psi for 9:00 with no drop
Test Passed

Line 1 segment between MH 1-4 & 1-5
Line held at 4psi for 7:34 with no drop
Test Passed

Comments: