

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191624
Address: 2700 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, August 05, 2020

Partial Correction:

1	Misc	-UNDERGROUND RACEWAYS TO LIGHT POLES-OK: UE FROM BUILDING TO NW AND SE LP; UE TO NORTH LP -UE FROM TRANSFORMER TO MDP OK -LP PIERS-OK: 5 NORTH LP AND SE LP PIER
---	------	--

Comments: