

  
**BOB D. CAMPBELL & CO.**  
Structural Engineers Since 1957  
4338 Belleview Ave. 816.531.4144  
Kansas City, MO 64111 www.bdc-engrs.com

PRINCIPALS

*President*

Michael J. Falbe, P.E.

Steven R. Carroll, P.E.

Richard C. Crabtree, P.E.

Wayne E. Davis, P.E.

Jeffrey L. Wright, P.E.

Christopher W. Boos, P.E.

Clark A. Basinger, P.E.

Brandon M. Ford, P.E.

Christopher A. Beverlin, P.E.

*Administrative Manager*

Paul M. Spena

August 5, 2020

Mr. CW Keller  
Slaggie Architects  
4600 Madison  
Kansas City, MO 64112

Re: Summit Orchards  
Gloss Nails and the Flying Biscuit TI demising walls

Dear CW:

We have reviewed the wall design for the Gloss Nails and the Flying Biscuit TI demising walls and find that it has the required strength and stiffness to resist the International Building Code lateral load of 5psf without any diagonal bracing/kickers provided the maximum wall height is 18'-0" or less.

Please call if you have any questions or if we may be of further service.

Sincerely,

**BOB D. CAMPBELL & CO.**  
*Structural Engineers*



Clark A. Basinger, P.E., Principal

cc: File / SLAGG1909

