

PLANS REVIEW CONDITIONS

Permit No: PRCOM20193580	Date: August 06, 2020
Project Title: FIREBIRDS WOOD FIRED GRILL	Applicant:
Location: 920 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081	FIRE & DATA SYSTEMS, INC. 104 GINGER LANE HAMLET, NC 28345
Type of Work:	Primary: (704) 582-1616
Occupancy Group: A-2	
Description: FULL SERVICE RESTAURANT WITH PATIO SEATING - FIREBIRDS WOOD FIRED GRILL	
Construction Type: Type VB (Unprotected)	
Map Page: 194D	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule alarm testing.

2. (Action Required)

Strobes only in restrooms

Eliminate horn/strobe in the outside patio area.

FACU in the space needs to be tied into the main FACU.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.