

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201001
Address: 1520 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, August 07, 2020

Corrective Action Required:

1	Misc	- Garage PFH per plans - bolts, nuts, washers missing - (3) 2x4 at corner HVAC to dining room framing per plans - continuous framing member - Truss hangers per plans - EC#2 per plans - UFER ground required
---	------	---

Comments: