CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200316

Address: 1704 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Gas Service Inspection - Robb Popp Passed Friday, August 07, 2020

Residential

Corrective Action Required:

1 Misc -COMPLETE B VENT AT FIREPLACE

-SECURE GAS LINE AT FIREPLACE

Comments: