

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20192517

Address: 2700 NE MCBAINE DR, Unit:IR, LEES SUMMIT, MO 64064
2700 NE MCBAINE DR, LEES SUMMIT, MO
64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Curb New/Replacement	John Jackson	Partial	Friday, August 07, 2020

Informational:

1 Misc

Contractor cut in ADA curbs for sidewalk crossing for driveway way approach on North entrance from street Mc Baine. Contractor also is removing curb five of curb on the Southwest corner of building project attached to the existing storm box. Structural failure to existing curb made it necessary to replace.

Comments: