

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192096  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Robb Popp	Partial	Friday, August 07, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE H2.5 CLIPS AT TRUSSES OVER ELEVATOR IN CORRIDOR 427
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	-BRACE TOP OF WALLS AT RETAIL 7 AND 8 ON ON EAST SIDE OF CORRIDOR 4' OC BY DOORWAYS -FASTEN END STUD/ TOP TRACK AT EAST WALL BY NORTH EXIT
---	--------------------------	---

Corrective Action Required:

3	Miscellaneous Correction	-BRACE TOP OF WALLS AT RETAIL 7 AND 8 ON ON EAST SIDE OF CORRIDOR 4' OC BY DOORWAYS -FASTEN END STUD/ TOP TRACK AT EAST WALL BY NORTH EXIT
---	--------------------------	---

**Comments:**