

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200874
Address: 1805 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-------------------------|
| All Rough Inspection - Residential | Robb Popp | Failed | Monday, August 10, 2020 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | **OK TO INSULATE-DO NOT SHEET ROCK -PROVIDE MIDPOINT STRAP ON ALL VERTICAL DWV 2" AND SMALLER THROUGHOUT-BASEMENT -ADDRESS WALL FRAMING NOT FULL PLATE HEIGHT PER PLANS AT GREAT ROOM AND ENTRY-PROVIDE ENGINEERED LETTER AND CORRECTION -SEAL PENETRATIONS IN PLENUMS-DWV PENETRATIONS IN BASEMENT -INSULATE AND BLOCK JOISTS AT GARAGE CANTILEVER-MISSING SW CORNER |
|---|--------------------------|--|

Comments: