

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182613  
Address: 905 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Monday, August 10, 2020

Corrective Action Required:

1	Miscellaneous Correction	-ABOVE CEILING FOR FRAMING AND SPRINKLER HEADS 4TH FLOOR PATIOS -FUR DOWN FRAMING AND FIRE CAULK ON 4TH FLOOR UNITS AND G1 AND G19 GARAGES -P TRAPS AND FIRE CAULKING TO COMPLETE MEP ON 1ST FLOOR
---	-----------------------------	--

**Comments:**