

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20201168  
Address: 2724 NE MCBAIN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Tuesday, August 11, 2020

Partial Correction:  
1 Misc IN-WALL OK TO ROCK: DEMISING WALLS

**CORRECTIONS REQUIRED:**

- Protect laundry rm plumbing from damage. Complete plumbing
- Support pvc vertically every ten ft or less
- Protect water lines where within 1.25" of stud/track surface
- Complete locker/bathroom wall and electrical

**Comments:**