

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20192859

Address: 492 NW CHIPMAN RD, LEES SUMMIT, MO 64086480 NW CHIPMAN RD, LEES SUMMIT, MO  
64086470 NW CHIPMAN RD, LEES SUMMIT, MO 64086460 NW CHIPMAN RD, Unit:IR,  
LEES SUMMIT, MO 64086460 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Construction Inspection</b>	Joe Starlin	Passed	Tuesday, August 11, 2020

Informational:

1	Misc	12-6-19 They have the vault set and are getting ready to pour the floor.
---	------	--

Informational:

2	Misc	12-10-19 9:16am The water is shut off for the water tie-in. They are cutting into the main at this time.
---	------	--

Informational:

3	Misc	12-10-19 9:16am The water is shut off for the water tie-in. They are cutting into the main at this time. 12:07pm They have the tie-in complete and are pouring the thrust block now. They will cover with a blanket due to weather.
---	------	---

Informational:

4	Misc	12-10-19 9:16am The water is shut off for the water tie-in. They are cutting into the main at this time. 12:07pm They have the tie-in complete and are pouring the thrust block now. They will cover with a blanket due to weather.
---	------	---

Informational:

5	Misc	12-11-19 1:55pm They have approximately 100ft running from the vault to the east. They have the right amount of rock and are running wire with the pipe.
---	------	--

Informational:

6	Misc	12-12-19 9:12am They have 80ft of waterline installed and have run 10ft of copper line out of the meter pit. 3:15pm They are still working on waterline.
---	------	--

Informational:

7

Misc

4-7-20 8:08am They have poured all thrust blocks and kickers for the fire lines. The west side fire line does not have rock around it at this time. I will inspect again after it is rocked. 1:44pm I have checked the fire line on the west end. It is rapped and rocked.

**Comments:**