

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20182613  
Address: 905 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Partial	Tuesday, August 11, 2020

Partial Correction:

1	Misc	-RELEASE SERVICE AT THREE TEMPORARY POST-MOUNTED SERVICES LABELED 901A, 901B, 901C
---	------	--

CORRECTION:

-ADJUST THE WEST SERVICE OVERCURRENT DEVICE TO 1000 AMP. THE EAST SIDE SERVICE IS OK

Comments: