

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193191
Address: 920 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Michael Harkins	Partial	Tuesday, August 11, 2020

Informational:
1 Misc

- WELDS APPROVED FOR 1ST LAYER WRAP -
- OK FOR SECOND LAYER WRAP -
- 2ND LAYER WRAP APPROVED -

Comments: