

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200316
Address: 1704 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, August 12, 2020

Informational:

1	Miscellaneous Correction	-portal framing hold downs and nailing pattern inspected-
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	**OK TO INSULATE ** -BRACED WALL PANEL AT BREAKFAST AREA TO BE PFH PER PLANS -BEDROOM TO BE CS-PF PER PLANS
---	--------------------------	--

Comments: