

DEVELOPMENT SERVICES

Building Permit - Commercial Permit No: PRCOM20200444
Project Title: CVS PHARMACY #8557 - HEALTHHUB Date Issued: August 12, 2020
Work Desc: ALTERATION COMMERCIAL

Project Address:

1900 NE LANGSFORD RD, LEES SUMMIT, MO 64086

Legal Description: MCKEE'S CORNER LOT 1

Parcel No: 60320204300000000

County: JACKSON

Permit Holder:

Groom Construction Company

96 Swampscott Road Salem, MA 01970

Activities Included for this Project:

zAlteration Commercial, License Tax, License Tax Credit, Above Ceiling Permit, Alarm Permit, Electrical Permit Commercial, In-Wall Inspection Permit, Mechanical Permit Commercial, Plumbing Permit Commercial, Sprinkler Permit,

Construction Type: Type IIB	Occupancy: MERCANTILE	Zoning District: CP-2
(Unprotected)	Valuation: \$150,000.00	

Residential Area:

Commercial Area sq. ft.

THIS PERMIT IS ISSUED IN RELIANCE UPON INFORMATION SUBMITED BY THE APPLICANT. THE BUILDING OFFICIAL MAY SUSPEND OR REVOKE WHENEVER THE PERMIT IS ISSUED IN ERROR, OR ON THE BASIS OF INCORRECT INFORMATION SUPPLIED, OR IN VIOLATION OF ANY ADOPTED CODE, CITY ORDINANCE OR REGULATIONS.

NOTICE: THE DISPOSAL OF DEMOLITION WASTE IS REGULATED BY THE DEPARTMENT OF NATURAL RESOURCES UNDER CHAPTER 260 RSMO. SUCH WASTE, IN TYPES AND QUANTITIES ESTABLISHED BY THE DEPARTMENT, SHALL BE TAKEN TO A DEMOLITION LANDFILL OR A SANITARY LANDFILL FOR DISPOSAL.

CONDITIONS

One or more divisions have conditions that have not been addressed during the review period. The outstanding conditions provided below shall be met as indicated during the construction period.

Licensed Contractors

Building Plan Review

Fire Plan Review

2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for

equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

(Action Required)

Any modifications to the fire alarm system, provide three sets of PE stamped shop drawings.

2 2018 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official. (Action Required)

Order a Knox box from knoxbox.com. Placement to be made by FDC.

2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation. (Action Required)

Any modifications to the fire sprinkler system, provide three sets of PE stamped shop drawings.

2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule alarm testing.

Provide exterior emergency lighting.

5 2018 IFC 1008.1 Illumination required. The means of egress, shall be illuminated at all times the building space served by the means of egress is occupied. (Action Required)

Signature of		
Applicant:	Date:	
Print name:	Company Name:	