

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201611
Address: 1713 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, August 13, 2020

Corrective Action Required:

1	Misc	- INTERIOR DRAIN TILE COVERED WITH GRAVEL, NO VISIBLE SUMP PIT, UNCOVER ALL INTERIOR DRAIN TILE FOR INSPECTION - SHOWER COVER OFF ON DWV
---	------	--

Comments: