

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200763
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mark Harding	Partial	Thursday, August 13, 2020

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	- CONDUIT FOR LIGHT POLE BASES NORTH , SOUTH & EAST OF BLDG - - CONDUIT FOR 2 POLE BASE SOUTH SIDE AT LOWENSTEIN -
---	--	---

Comments: