

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20201062  
Address: 1804 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Thursday, August 13, 2020

Corrective Action Required:

1	Miscellaneous Correction	***OK TO INSULATE***  -PROVIDE 20 AMP DEDICATED CIRCUIT IN GARAGE PER CODE-THE 3 RECEPTACLES FOR WALL OUTLETS-ONE PER CAR BAY.—ADD THE ONE FOR THE SINGLE BAY THIS WAS PRESENT BUT GOT REMOVED WHEN SWITCHED OVER TO 20 AMP  -ADDRESS OVER CUT LVL HIPS IN GREAT ROOM AND MASTER CLOSET  -SUPPORT PVC FOR COMBUSTION AIR PER CODE
---	--------------------------	---

**Comments:**