

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200874
Address: 1805 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, August 13, 2020

Corrective Action Required:

1	Miscellaneous Correction	**OK TO INSULATE-DO NOT SHEET ROCK -ADDRESS WALL FRAMING NOT FULL PLATE HEIGHT PER PLANS AT GREAT ROOM AND ENTRY-PROVIDE ENGINEERED LETTER AND CORRECTION
---	--------------------------	--

Comments: