

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200845

Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Thursday, August 13, 2020

Corrective Action Required:

1 Miscellaneous
Correction

-FOLLOWING AREAS APPROVED:

CONDUIT FROM ELECTRICAL ROOM 1B108 ABOUT 100' TO SPLIT FOR PANELS B130 & B131, ROOM1B00J AND AMBULANCE BAY PANELS B125 & 126

POLE - CONDUIT;
SOUTH EXISTING POLE TO ADDED; NEW WEST POLES FROM SOUTH CORNER OF
NEW LOT NORTH 200FT.

-CONDUIT FROM EXISTING BUILDING TO NEW GENERATOR AT NORTHEAST
PARKING LOT

-CONDUIT AND GROUND RODS FOR LIGHT POLES IN SOUTHWEST LOT 5 OF 7

Comments: