

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20201843  
Address: 390 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	Michael Harkins	Passed	Thursday, August 13, 2020

Informational:  
1 Misc

- UFER PER PLAN -
- DRIVEN GROUND ROD UNDER FOOTING -
- UNDER SLAB CONDUIT IN PLACE -

**Comments:**