

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Storm - Sewer Construction Inspection	John DiMauro	Passed	Thursday, August 13, 2020

Informational:

13 Misc

Redford Construction has a crew on site to repair the 6 damaged curb inlet structures. The repairs appear to be acceptable according to the discussion I had with Steve Robbins on a repair solution. Photos of the repairs are uploaded.

Comments: