

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201235
Address: 2935 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, August 13, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Post address- Remove siding front garage to allow inspection of foundation portal straps- Security blocking at back door- Secure all DWV 2" or less at mid point- Fireblock deadspace front bedroom #5- Remove front porch lid to allow inspection of all truss hangers- EC#2 per plans- Install structural plate straps on all plates bored more than 50%. |
|---|------|--|

Comments: