

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200871
Address: 4407 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, August 14, 2020

Corrective Action Required:

1	Misc	- Garage PFH per plans - Truss hangers per plans - front porch, back porch - Structural strap at top plate bored for DWV in bearing wall bedroom #3
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: