

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192096
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Monday, August 17, 2020

Corrective Action Required:

1	Miscellaneous Correction	RETAIL AREA "B"
---	-----------------------------	-----------------

-AREAS APPROVED-

-CORRIDOR 103 WEST WALL FROM COLUMN LINE 2 TO 4.4 EXTERIOR
SHEATHING SCREW PATTERN

Corrective Action Required:

2	FIRST FLOOR	AREA "E"
---	-------------	----------

-AREAS APPROVED-

RC CHANNEL ROOMS 128,133 CEILINGS
RC CHANNEL ROOMS 125,126,127,129,134,135 WALLS AND CEILING

Corrective Action Required:

3	SECOND FLOOR	AREA "E"
---	--------------	----------

-AREAS APPROVED-

RC CHANNEL CORRIDOR 222
RC CHANNEL CORRIDOR 226 TO ROOM 250
RC CHANNEL WALLS AND CEILING 240,264

		SCREW PATTERN ON FIRST LAYER WALLS CORRIDOR 219 TO ROOM 241, CORRIDOR 222 TO STAIRS
Corrective Action Required:		
4	THIRD FLOOR	AREA "E"
		-AREAS APPROVED-
		RC CHANNEL CORRIDOR 322 TO CORRIDOR 326 RC CHANNEL CORRIDOR 326 AND 327
		SCREW PATTERN ON CEILING CORRIDOR 322 SCREW PATTERN ON CEILING CORRIDOR 326 TO ROOM 355
		SCREW PATTERN ON FIRST LAYER WALLS CORRIDOR 319 TO ROOM 341, CORRIDOR 322 TO STAIRS
Corrective Action Required:		
5	FOURTH FLOOR	AREA "E"
		-AREAS APPROVED-
		RC CHANNEL CORRIDOR 422, CORRIDOR 426 RC CHANNEL CORRIDOR 427
		SCREW PATTERN ON FIRST LAYER WALLS CORRIDOR 419 TO ROOM 439 SCREW PATTERN ROOMS 439,440,441,442,443,459,460

Comments: