

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200837
Address: 1417 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, August 18, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Fireblock/solid block above top plate between floor joists at owner entry/pantry from garage- EC#2 per plans- 3" SCH 40 steel column at pier location "B" in basement per plans- 3" SCH 40 steel column at W12x16 beam in garage per plans- Anchor all columns to floor in basement- Truss hangers per plans- Trusses missing at front porch per plans- Secure electrical box at front porch- Truss bracing per plans
---	------	---

Comments: