



DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

August 12, 2020

LYNN ELECTRIC & COMMUNICATIONS INC
725 N 2ND ST STE K
LAWRENCE, KS 66044

Permit No: PRCOM20202284
Project Title:
Project Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081
Parcel Number: 51800043700000000
Location: STREETS OF WEST PRYOR LOTS 1-14 & TRACTS A-D: LOT 8 (EX TH PT LOT 8 DAF: ALL TH SPACE
BETWEEN NAVD8 DEG 27 MIN 16 MIN W 41.99' TO TRU POB TH S 87 DEG 32 MIN 44 SEC E
27.69' TH N 02 DEG 27 MIN 16 SEC E E 29.33' TH S 02 DEG 27 MIN 16 SEC W 36' TH N 87 DEG
32 MIN 44 SEC W 2' TH S 02 DEG 27 MIN 16 SEC W W 4' TH S 02 DEG 27 MIN 16 SEC W 22.67'
TH S 87 DEG 32 MIN 44 SEC E 4.67' TH S 02 DEG 16 MIN 27 SEC
Type of Work: REPAIR REPLACE UPGRADE
Occupancy Group:
Description: 200 AMP SINGLE PHASE UNDERGROUND TEMP METER AND PANEL FOR JOBSITE POWER.

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Dylan Eppert

Approved

____ Approved to issue per the listed conditions.
____ Do not issue per the listed conditions.
____ Approved to construct foundation only per the listed conditions.
____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.